

DISTRICT WATER TESTING LABORATORY, KAPURTHALA

Near Dhaliwal dona,water works,Kapurthala
dwtlkpt@gmail.com

To,

ALPINE PUBLIC HIGH SCHOOL BHANTURE KALAN
KAPURTHALA

No.: DWTLKPT/2627/00036 Dated : 15/05/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 3253 Dated: 12/05/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 12/05/2026. It is request to fill the attached feedback form and send it back to District water Testing Laboratory, Kapurthala

D/A : Test Report



Authorized Signatory
For, District water Testing Laboratory
Kapurthala

DISTRICT WATER TESTING LABORATORY, KAPURTHALA

Near Dhaliwal dona,water works,Kapurthala
dwtlkpt@gmail.com



TEST REPORT

Name & Address of Customer : ALPINE PUBLIC HIGH SCHOOL BHANTURE KALAN KAPURTHALA		Customer Reference No.	No : 3253 Dated : 12/05/2026
		Sample Submitted by	MR INDERJIT SINGH
		Date of Sample Receipt	12/05/2026
		Analysis Starting Date	14/05/2026
		Analysis completion Date	15/05/2026
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC14459260000160F	Sample Type :	Water
Test Report No.:	DWTLKPT/2627/00036	Date of Issue :	15/05/2026
Registration no.:	DWTLKPT/REG2627/00159	Condition of Sample :	Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Transparent Glass Bottle
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	ALPINE PUBLIC SCHOOL BHANTURE KALAN / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Nadala	District :	Kapurthala
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.01	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	90	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.50	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO ₃)	51.74	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO ₃)	36.00	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	6.41	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	4.86	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	5.95	250	1000	mg/l	IS 3025 (Part 32-2025) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Mr. Jivesh Kumar
Microbiologist/Analyst
Authorized Signatory
For, District water Testing Laboratory
Kapurthala

----- End of the Test Report -----